

Ames Company, Inc.

(Company) Auth. No. 271

Date: 91/06/28 Under A.S.S.E. Standard: 1048 1990

Double Check Detector Assembly

MODELS: 3000 SS 2-1/2, 3, 4, 6 in.

horizontal & vertical flow up

tested w/ waterous r/w gate valve OS & Y  
add Kennedy shutoff to 4,6inch 11/11/93

has been renewed and will be in effect until: 9897/06/

Date: 97/05/28

## **ASSE SEAL AUTHORIZATION NOTICE**


**American Society of Sanitary Engineering**

28901 Clemens Rd., Suite 100

Westlake, OH 44145

Phone: (216) 835-3040 • Fax: (216) 835-3488

# AMERICAN SOCIETY OF SANITARY ENGINEERING

For Plumbing and  Sanitary Research

This certifies that Ames Company, Inc. is authorized to display the A.S.S.E. Seal on its Double Check Detector Assembly Model 3000 SS 2½, 3 & 4 in. horizontal & vertical flow up in the manner and under the conditions stated herein and any supplemental description sheets, in accordance with A.S.S.E. Standard Number. 1048 - 1990

Tested USC - FCCC & HR

This authorization is issued for one (1) year from date hereon and is renewable annually for a period of five (5) years subject to the conditions printed on the reverse side of this certificate.

The SEAL displayed on a product indicates that the product has been tested for compliance with an appropriate and accepted A.S.S.E. Standard for performance in a system of plumbing.

The American Society of Sanitary Engineering has created the SEAL program to encourage improvements in plumbing products and systems in the interests of greater protection of public health and safety.

DATE August 5, 1991

CHAIRMAN

  
A.S.S.E. SEAL BOARD