



December 21, 2009

Joseph Burke, P.E.
Watts Regulator
815 Chestnut Street
Andover, MA 01845

Dear Mr. Burke:

NSF has reviewed the submission identified below. Based on the product literature, product specifications, metal certification statements and product drawings submitted, the product(s) covered contain a weighted average lead content of less than or equal to 0.25%.

0107000 2 1/2 X 1 7/8 W-SPL	0107039 8 x 16 1/2 W-SPL
0107001 2 1/2 X 3 3/8 W-SPL	0107040 8 x 17 3/8 W-SPL
0107002 2 1/2 x 3 15/16 W-SPL	0107041 8 x 18 3/8 W-SPL
0107003 2 1/2 x 4 W-SPL	0107042 8 x 21 1/16 W-SPL
0107004 2 1/2 x 4 15/16 W-SPL	0107043 8 x 21 1/8 W-SPL
0107005 3 x 1 7/8 W-SPL	0107044 8 x 22 3/8 W-SPL
0107006 3 x 2 1/2 W-SPL	0107045 8 x 22 7/8 W-SPL
0107007 3 x 3 1/2 W-SPL	0107046 8 x 23 3/8 W-SPL
0107008 3 x 3 15/16 W-SPL	0107047 8 x 25 5/8 W-SPL
0107009 3 x 4 W-SPL	0107048 10 x 16 1/8 W-SPL
0107010 4 x 5 3/8 W-SPL	0107049 10 x 16 3/4 W-SPL
0107011 4 x 5 7/8 W-SPL	0107050 10 x 28 1/8 W-SPL
0107012 4 x 6 3/8 W-SPL	0107051 10 x 28 3/8 W-SPL
0107013 4 x 6 13/16 W-SPL	0107052 10 x 28 1/2 W-SPL
0107014 4 x 7 3/8 W-SPL	0107053 10 x 29 7/8 W-SPL
0107015 4 x 7 15/16 W-SPL	0107054 10 x 29 15/16 W-SPL
0107017 4 x 9 7/8 W-SPL	0107055 10 x 32 3/8 W-SPL
0107018 4 x 10 1/4 W-SPL	0107056 10 x 32 7/16 W-SPL
0107019 4 x 10 7/8 W-SPL	0107057 10 x 34 3/8 W-SPL
0107020 4 x 11 7/8 W-SPL	0107058 10 x 37 3/4 W-SPL
0107021 4 x 12 W-SPL	0107105 2 1/2 x 3 3/4 W-SPL
0107022 4 x 14 7/8 W-SPL	0107106 2 1/2 x 5 1/4 W-SPL
0107023 6 x 5 1/8 W-SPL	0107107 3 x 8 1/16 W-SPL
0107024 6 x 8 3/8 W-SPL	0107108 3 x 8 11/16 W-SPL
0107025 6 x 9 11/16 W-SPL	0107109 4 x 12 9/16 W-SPL
0107026 6 x 10 1/4 W-SPL	0107110 4 x 13 9/16 W-SPL
0107027 6 x 11 W-SPL	0107111 6 x 18 1/4 W-SPL
0107028 6 x 12 7/16 W-SPL	0107112 8 x 25 1/4 W-SPL
0107029 6 x 12 1/2 W-SPL	0107113 10 x 30 1/4 W-SPL



0107030 6 x 13 3/8 W-SPL	0107076 4 x 1/2 W-FLG Z-U
0107031 6 x 13 7/8 W-SPL	0107068 3 x 1/2 W-FLG Z-U
0107032 6 x 14 W-SPL	0107067 2 1/2 x 1/2 W-FLG SS-S
0107033 6 x 14 3/8 W-SPL	0107072 3 x 1/4 W-FLG SS-U
0107034 6 x 14 7/8 W-SPL	0107073 3 x 1/2 W-FLG SS-U
0107035 6 x 16 7/8 W-SPL	0107075 3 x 1/2 W-FLG SS-S
0107036 6 x 17 3/8 W-SPL	0107080 4 x 1/4 W-FLG SS-U
0107037 8 x 12 1/8 W-SPL	0107081 4 x 1/2 W-FLG SS-U
0107038 8 x 16 1/8 W-SPL	

The weighted average lead content has been calculated using the following formula: The percentage of lead content within each component that comes in contact with water was multiplied by the percent of the total wetted surface of the entire product represented in each component containing lead. These percentages were added and the sum constitutes the weighted average lead content of the product.

These products also meet the requirements of NSF Low Lead Certification Program. For a listing of NSF Certified products, visit www.nsf.org. This letter remains active for one (1) year.

Sincerely,

Nancy M. Cistulli
Certification Project Manager
Plastic Piping System Components

Email: ncistulli@nsf.org
Phone: 734-827-5673
Fax: 734-827-7895