

Northbrook, Illinois • (847) 272-8800  
 Melville, New York • (516) 271-6200  
 Santa Clara, California • (408) 985-2400  
 Research Triangle Park,  
 North Carolina • (919) 549-4400  
 Camas, Washington • (206) 877-5500



AMES CO INC  
 MR L ENGELMANN  
 1485 TANFORAN AVE  
 P O BOX 1387  
 WOODLAND CA 95776

**RE: Project Number(s) - 00RS505238**

Your most recent listing is shown below. Please review this information and report any inaccuracies to the UL Engineering staff member who handled your project.

For information on placing an order for UL Listing Cards in a 3 x 5 inch format, please refer to the enclosed ordering information.

BAEU  
 Backflow Special Check Valve Devices

July 13, 2000

AMES CO INC  
 1485 TANFORAN AVE P O BOX 1387, WOODLAND CA 95776

EX3872

Backflow special check valves for a max. working pressure of 175 psi in the following models, types and sizes:

Model	Type	Size In.	Installation Orientation
2000B	DC	3/4,1-1/4,1-1/2	H, V
2000B	DC	1,2	H, V
2000CIV	DC	4,6,8,10	H
2000DC	DC	10	H
2000DCA	DC	8	H
2000SE	DC	2-1/2,6,8	H, V
2000SS	DC	2-1/2,3,4,6,8,10,12	H, V
2000SSF	DC	2-1/2, 3, 4	H
2001SS	DC	3,4,6,8	H, V
2001SSN	DC	3,4,6,8	H
2001SSZ	DC	3,4,6,8	H
3001SS	DCD	3,4,6,8	H, V
3001SSN	DCD	3,4,6,8	H
3001SSZ	DCD	3,4,6,8	H
3000B	DCD	2,2-1/2	H, V
3000CTV	DCD	4,6,8,10	H
3000DCDC	DC	10	H
3000SE	DC	2-1/2,6,8	H, V
3000SS	DC	2-1/2,3,4,6,8,10,12	H, V
3000SSF	DCD	2-1/2, 3, 4	H
4000B	RP	3/4, 1-1/4, 1-1/2, 2	H, V
4000B	RP	1	H, V
4000CTV	RP	2-1/2, 3, 4, 6, 8, 10	H
4000RP	RP	6,8,10	H